

Customer Info

Janella TEST Flook TEST
11835 Crystal Falls Dr
Smithsburg Md 21783

County Washington

System Data

System Model SINGULAIR TNT-500GPD

Aerator Serial # 82A3G2S

Aerator Air Pump Model SINGULAIR 206C

AERATOR

Control Model SERVICE PRO TNT

Control Serial # 988654Z

Bi-Annual Service

Service Call Routine

Inspection Date October 7, 2021 11:22 AM

Customer Present? N

In Addition to the service work performed during a routine service call, The service technician performed the following:

Aerator Service: Shaft cleaned

Bio-Kinetic System: Clean system installed

Control Center: Ok

Effluent Disposal System: System working properly

Auxiliary Equipment: None

Other Work Performed: , Preform routine 6 month service

System Conditions:

Pump Out Notice: No

Aerator Amperage: 4.5

Water Level in Plant: Normal

Effluent Quality: Normal

Aerator Vibration: N

Aerator Noise: N

Plant Odor: N

Service Technician Name

Jerry

Service Call Routine

Inspection Date October 12, 2021 10:58 AM

Customer Present? N

In Addition to the service work performed during a routine service call, The service technician performed the following:

Aerator Service: Shaft cleaned no issues

Bio-Kinetic System: Reinstalled biokinetic system after cleaning

Control Center: Control center checked, all good

Effluent Disposal System: Effluent disposal system clear

Auxiliary Equipment: None

Other Work Performed: None

System Conditions:

Pump Out Notice: No
Aerator Amperage: 4.2
Water Level in Plant: Normal
Effluent Quality: Gray
Aerator Vibration: N
Aerator Noise: N
Plant Odor: N

Service Technician Name

Jerry

Sample Report